

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7258-1521:107 Page 1 of 1

**CATEGORY:** Combination Ionization/Photoelectric Smoke Detector

**LISTEE:** Siemens Building Technologies, Inc., 1000 Deerfield Parkway, Buffalo Grove, IL 60089  
Contact: \*Ferd Orpano (847) 941-6176 FAX (866) 699-0238

**DESIGN:** Model SIGA-IPHS and SIGA-IPHS-LG combination ionization/photoelectric smoke detector. Units have a built in heat sensor. Refer to listee's data sheet for detailed model descriptions and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Model number, electrical rating, UL label, and Listee's name.

**APPROVAL:** Listed as an combination ionization/photoelectric smoke detector for use with listee's separately listed base (CSFM Listing No. 7300-1521:106) and separately listed compatible fire alarm control units.

**NOTE:**

1. The integral heat sensor is a supplement to the smoke detector. Not approve for use in lieu of required heat detector.
2. Formerly 7258-1469:107

**XLF:** 7258-1591:123\*

\*Rev. 07-24-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 24, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager